

**SECONDARY CONTAINMENT DRAINAGE REPORT**  
(AS APPLICABLE)

Facility Name: \_\_\_\_\_

Date	Time	Secondary Containment Identification	Volume Released (gallons)	Water Inspection Results	Name of Inspector

**Secondary containment drainage procedure:**

1. Examine the surface of the water in the secondary containment structure to be drained. Hydrocarbons must not be present (oil sheen) or release will not be allowed.
2. When the water is free of hydrocarbons, unlock and open the drain valve (if applicable).
3. Stay at the open valve continuously and monitor the water discharge.
4. Close and lock the drain valve when the water is drained.
5. Complete the secondary containment inspection and drainage report and file with the SPCC Plan.